



Karnataka State Fire & Emergency Services
Office of the District Fire Officer
Sarjapura-Road Fire Station, Bengaluru-560035.
Ph : 080-25746166



C.NO: 38/DFO/SRFS/FSR/BNG/2025

Dt: 07-07-2025

To,
The Authorized Signatory
M/s. Vidya Siri International School,
(A unit of kashipathi Educational trust)
Sy No: 67/4, Kodthi Village,
Varthur Hobli, Bangalore East Taluk,
Bangalore-560 035.

" Annexure--2 "
Educational Buildings

Sir,

Sub: Issue of **"Fire safety Recommendation Certificate"** to **"M/s. Vidya Siri International School, (A unit of kashipathi Educational trust) ,Sy No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035"**.

Ref: 1) Your Request letter Date: 23/04/2025:

2) FSO Inspection report no.38/FSO/SRFS/BNG/2025. Dt: 25/04/2025.

<<<<<>>>>>

With reference to the subject cited above, the premises **"M/s. Vidya Siri International School, (A unit of kashipathi Educational trust) ,Sy No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035"** was inspected by Fire Station officer Sarjapura-road fire station, Bangalore on **Dt:25-04-2025** for suggesting fire prevention, fire fighting & evacuation measures. The details are as follows:-

A.Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Authorized Signatory M/s. Vidya Siri International School, (A unit of kashipathi Educational trust) Sy No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035
02	Name and Address of the premises.	:	M/s. Vidya Siri International School, (A unit of kashipathi Educational trust) Sy No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035
03	Name and address of the Building owner	:	Smt K.K.Indira Devi No: 56, 1 st main road, palace Guttahalli Bangalore-560003,
04	Number of buildings		One Building
05	Number of floors		Ground plus and 4 upper floors.



06	Floor-wise details of occupancy:-		
	Ground floor	:	02 Class Rooms, 01 front Office, 01 Reception, 01 Board room, 01 principal room, 01 pantry, 01 admin office, 01 first aid room, 01 staff room.
	1 rd floor	:	04 Class Rooms, 01 staff room, 01 store room.
	2 nd floor	:	03 Class Rooms 01 Computer lab.
	3 rd floor	:	02 Class Rooms, 00 labs, 01 Common room, 01 Counseling room.
	4 th floor	:	04 Class Rooms, 01 Extra Curricular room, 01 Common room.
07	Height of the building	:	14.85 Mtrs.
08	Site area	:	529.00 Sq. Mtrs
09.	Built-up area of each floor:-		
	Ground floor	:	428.37 Sq. Mtrs.
	1 rd floor	:	428.37 Sq. Mtrs.
	2 nd floor	:	428.37 Sq. Mtrs.
	3 rd floor	:	428.37 Sq. Mtrs.
	4 th floor	:	428.37 Sq. Mtrs.
10.	Total built-up area	:	2141.85 Sq. Mtrs.
11.	Surrounding properties:-		
	West (Front)	:	09.00 mtrs wide Chikkakanalli main road
	East (Rear)	:	Vacant land
	North (Side)	:	Vacant land
	South (Side)	:	Vidya siri College
12.	Set-back area available around the building :-		
	West (Front)	:	04.00 mtrs
	East (Rear)	:	04.00 mtrs
	North (Side)	:	02.00 mtrs
	South (Side)	:	02.00 mtrs

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The Premises is accessible from 10.00 mtrs wide Chikkakannalli main road located on Eastern side the road is hardened to carry the Weight of 45.000 Kgs.	Adequate
02.	No. of entrances	One entrance / exit have been Provided.	Complied
03.	Width of entry / exit	Entrance / Exit- 06.20 mtrs.	Adequate
04.	Diesel generators.	One No generator of 65KVA Capacity has been provided it has been connected to all emergency fire fighting & lighting systems.	Complied
05.	No. of staircases	Nos. of staircases : 02	Complied




	available	Width of staircases	:	Each of 1.90 mtrs	
		Width of treads	:	30 cm	
		Height of risers	:	15 cm	
		Nos. of riser per flight	:	12	
		Height of handrails	:	1.15 mtrs	
		Head room clearance	:	3.20 mtrs	
06.	No. lifts and capacity.	Nos. of lifts	:	01	Complied
		Capacity of lifts	:	08 passengers	
07.	Fire extinguisher	05 Nos. of ABC fire extinguishers, each Of 6 kg capacity & 02 No's of Co2 fire extinguishers Of 4.5 kg capacity has been provided in each floor of the building.			Complied
08.	First aid Hose reel hose.	One No Hose Reel Hose System has been provided near the staircase of 19 mm size of adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5 mm size. Has been Provided in each floor of the building.			Complied
09.	Terrace tank over respective tower terrace.	10,000 liters capacity of terrace tank has been provided for each hose real hose systems.			Complied
10.	At the terrace tank level with minimum pressure of 3.5kg/cm ²	A booster pump has been installed at the terrace level capable of delivering 450 liters of water per minute.			Complied
11.	Escape routes	Escape routes have been Marked in which visibly to guide the students make to safer Places.			Complied
12	No Smoking Board	Displayed			Complied
13	Fire Siren	A Fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.			Complied
14	Nominate one fire no Nodal Officer	One non-teaching staff has been Sri Sunil nominated as fire nodal officer for the school premises.			Complied
15.	Fire order	A notice board has been displayed the Action to be taken by the school staffs in Case of an emergency with Telephone Numbers of Sarjapur Road Fire Station i.e. 25746166 & 101 and telephone numbers of nearest Ambulance Service & Management Has been displayed.			Complied
16.	Fire fighting training	Not Trained			40% of teaching & non-teaching staff should be got trained in fire prevention and fire



			fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore-560 029 or Regional Training center.
17.	General Fire precaution measures :- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustible waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should be not stored in the building. E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction. F. During the class hours the class room doors shall not be locked from inside to outside. G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department. H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.		

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation Certificate" to "M/s. Vidya Siri International School, (A unit of kashipathi Educational trust) , Sy No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035", subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 03 months and compliance from the undersigned.

Yours faithfully,


DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560035



Karnataka State Fire & Emergency Services
Office of the District Fire Officer
Sarjapura-Road Fire Station, Bengaluru-560035.
Ph : 080-25746166



C.NO: 38/DFO/SRFS/FSCR/BNG/2025

Dt: 07-07-2025

To,
The Authorized Signatory
M/s. Vidya Siri International School,
(A unit of kashipathi Educational trust)
Sy No. 67/4, Kodthi Village,
Varthur Hobli, Bangalore East Taluk,
Bangalore-560 035.

" Annexure--2 "
Educational Buildings

Sir,

Sub: Issue of "**Fire Safety Compliance Certificate**" with respect to fire prevention, fire-fighting
And Evacuation measures maintained at "M/s. Vidya Siri International School, (A unit of
kashipathi Educational trust), Sy.No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East
Taluk, Bangalore-560 035"

- Ref: 1) DFO office FSR No: 38/DFO/SRFS/Bng/FSR/2025. Dt:-25-04-2025.
2) Your request letter dated: 23-04-2025.
3) FSO Inspection report no.:38/FSO/SRFS/BNG/2025. Dt:-25/04/2025.

<<<<>>>>

With reference to the above cited subject, as per reference(1) a conditional Fire Safety Recommendation was issued to the premises of "**M/s. Vidya Siri International School, (A unit of kashipathi Educational trust)Sy No: 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035**" With a Condition to fulfill the recommendations and compliance the same within 03 months.


With reference cited (2) above, the management "**M/s. Vidya Siri International School**, had requested for Issue of fire safety compliance report from our department. In this regard the Fire Station officer, Sarjapura road Fire Station, Bangalore was inspected the building on **dt: 25-04-2025** and submitted the report recommending to Issue the fire safety Compliance Certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is Issuing the "**Fire Safety Compliance Certificate**" to "**M/s. Vidya Siri International School, (A unit of kashipathi Educational trust) , Sy No. 67/4, Kodthi Village, Varthur Hobli, Bangalore East Taluk, Bangalore-560 035**", subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees are training within 03 months from the date of issue of this Certificate.

"This Certificate is valid till 24-04-2027 and is renewable without fail".



Yours faithfully,


DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560035